


**NOTES:**

1. FOR LEGEND, ABBREVIATIONS, AND GENERAL NOTES, SEE DWG. E-1. FOR INSTALLATION DETAILS, SEE DWG. E-2. FOR WIRING DIAGRAMS, SEE DWG. E-3.
2. REPLACE EXISTING STROBE WITH THE SHOWN CANDELA RATED STROBE, AND REWIRE AS SHOWN. EXISTING BACKBOX AND CONDUIT STUB CAN BE UTILIZED IF IT IS SIMILAR TO THE TYPICAL STROBE OR COMBINATION BOX. SEE INSTALLATION DETAIL "B" ON DWG. E-2.
3. ONLY AFTER INSTALLED STROBES ARE TESTED AND OPERATIONAL, SHALL CONTRACTOR REMOVE EXISTING STROBE IN THE PRESENCE OF THE ENGINEER. PATCH WALL TO MATCH EXISTING WALL FINISH.
4. SINCE FIRE ALARM CIRCUIT LENGTH IS CRITICAL, ROUTING AND INSTALLATION OF ALL FIRE ALARM CIRCUITS SHALL BE AS SHOWN ON DRAWING.
5. DISCONNECT AND ABANDON EXISTING STROBE CIRCUITS IN CEILING. TAPE ENDS OF ABANDONED CONDUCTORS AND TAG AS ABANDONED. THIS WORK SHALL BE DONE IN THE PRESENCE OF THE ENGINEER.

**STROBE CIRCUIT/LOADING TABLE**

STROBE TYPE AND RATING	TYPE	15cd	30cd	75cd	110cd	CURRENT IN AMPS (A)	CURRENT PER CIRCUIT (AMPS.)	CIRCUIT LENGTH (ft.)
QUANTITY OF STROBES PER CIRCUIT	STR-A	9	2	1	0	0.063	0.209	416
	STR-B	8	1	1	1	0.100	0.209	508
	STR-C	7	3	0	1	0.165	0.209	346
	STR-D	3	0	2	2	0.100	0.209	321
	STR-E	6	1	3	0	0.100	0.209	344
	STR-F	7	3	1	0	0.165	0.209	484
GRAND TOTAL						5.676		2419



0 12 24  
SCALE IN FEET

**WORLD TRADE CENTER**  
CONTRACT NO. 3

**ENGINEERING DEPARTMENT**  
DESIGN DIVISION  
WORLD TRADE CENTER  
CONTRACT NO. 3

**ELECTRICAL**  
Title  
FIRE ALARM SYSTEM  
DEVICE UPGRADE  
PHASE III  
1 WORLD TRADE CENTER  
CONTRACT NO. 3  
87th FLOOR  
STROBE  
INSTALLATION AND  
REMOVAL PLAN

This drawing subject to conditions in Contract. All inventions, ideas, designs and methods herein are reserved to Port Authority and may not be used without its written consent.

S. FELDSTEIN N. APOSTLE A.S.  
Designed by Drawn by Checked by

AUGUST 9, 1999  
Date

WTC-861.178 E-087-4  
Contract Number Drawing Number